



REPORT TO THE CITY OF HELENA

Section 11: Constitution Park

July 24, 2015

Legend of Abbreviations

aff...	Above the finished ground
AR...	Accessible Route
CIL...	Change in Level
CFS...	Clear Floor Space
CGS...	Clear Ground Space
EPC...	Elevated Play Component
GLPC...	Ground Level Play Component

Background

The RAC staff visited Constitution Park to conduct an access audit. The findings are below.

1.1 Parking – not applicable

1.2 Exterior Accessible Route - [CHECKLIST] 1.25" CIL [CO1](#), [CO2](#), pavers shifting at display [CO7](#), [CO8](#); 4" gap [CO9](#), [CO10](#); 6.8% cross slope [CO3](#), [CO4](#); 6.3% running slope [CO5](#), [CO6](#)

Recommendations (in the alternative, leave as is and designate other sites in the City as accessible):

- 1.2.1 **Repair, bevel, or ramp** CIL along AR (CO1, CO2)
- 1.2.2 **Repair** and reset pavers to eliminate CIL and gaps (CO7, CP8)
- 1.2.3 **Correct or fill** gaps along AR (CO9, CO10)
- 1.2.4 **Correct or repair** sidewalk cross slope along AR to max 2.08% (CO3, CO4)
- 1.2.5 **Correct or repair** sidewalk running slope along AR to max 5% (CO5, CO6)

Responsible Employee	Progress Towards Completion	Recommended Phase
Amy Teegarden Director 406/447-8462	(insert periodic notes regarding steps taken or work completed)	CITY OPTION

1.3 Playground Designated Entry - not applicable

1.4 Playground Surface/Accessible Route within - not applicable

1.5 Transfer System - not applicable

1.6 Ramps - not applicable

1.7 Elevated Play Components - not applicable

1.8 Ground Level Play Components - not applicable

1.9 Sand box/Play tables - not applicable

1.10 Park Site - [CHECKLIST]

Constitution Shelter (1): stairs [CO11](#)

Garbage Can (1): no issues

Christmas Tree Post (1): no issues

Benches (2): no issues

Picnic Tables (1): noncompliant (checklist)

Recommendations (in the alternative, leave as is and designate other sites in the City as accessible):

1.10.1 **Provide** ramped entrance to constitution shelter (CO11)

1.10.2 **Replace or add one picnic table** with one with knee and toe clearance, 19” deep at 27” high and 24” deep at 9” high, with a 36” AR around table as a smart practice (checklist)

Responsible Employee	Progress Towards Completion	Recommended Phase
Amy Teegarden Director 406/447-8462	(insert periodic notes regarding steps taken or work completed)	CITY OPTION

1.11 Shelters/Picnic Areas - not applicable

1.12 Park Buildings - not applicable

1.13 Other - not applicable

CITY OF HELENA CONSTITUTION PARK