



REPORT TO THE CITY OF HELENA

Section 22: Janet Park

August 3, 2015

Legend of Abbreviations

| | |
|----------------|-----------------------------|
| aff... | Above the finished ground |
| AR... | Accessible Route |
| CIL... | Change in Level |
| CFS... | Clear Floor Space |
| CGS... | Clear Ground Space |
| EPC... | Elevated Play Component |
| GLPC... | Ground Level Play Component |

Background

The RAC staff visited Janet Park to conduct an access audit. The findings are below.

1.1 Parking – not applicable

1.2 Exterior Accessible Route - [\[CHECKLIST\]](#) lacks AR to all site elements (checklist)

Recommendations (Janet Park is a site designated as accessible so 1.2.1 is integral to compliance with title II program access test):

1.2.1 Create AR with crushed and compacted stone or similar outdoor material from parking or sidewalk to the site elements (checklist)

| Responsible Employee | Progress Towards Completion | Recommended Phase |
|---|---|--------------------------|
| Amy Teegarden Director 406/447-8462 | (insert periodic notes regarding steps taken or work completed) | PHASE TWO |

1.3 Playground Designated Entry - not applicable

1.4 Playground Surface/Accessible Route within - not applicable

1.5 Transfer System - not applicable

1.6 Ramps - not applicable

1.7 Elevated Play Components - not applicable

1.8 Ground Level Play Components - not applicable

1.9 Sand box/Play tables - not applicable

1.10 Park Site - [\[CHECKLIST\]](#)

Trail (1): noncompliant [JA2](#), [JA3](#), [JA4](#)

Gardens (23): lacks AR [JA6](#), [JA7](#), [JA8](#), [JA9](#), [JA10](#)

Benches (2): lacks CFS [JA4](#); lacks armrests (checklist)

Picnic Tables (1): noncompliant

Recommendations (Janet Park is a site designated as accessible so 1.10.1 through 1.10.4 is integral to compliance with title II program access test):

- 1.10.1 **Replace** trail surface with crushed and compacted stone or similar outdoor material (JA2, JA3, JA4)
- 1.10.2 **Create AR** with crushed and compacted stone or similar outdoor material from parking or sidewalk to the gardens (JA6, JA7, JA8, JA9, JA10)
- 1.10.3 **Construct firm, stable, and slip resistant pads** at least 36” by 48” adjacent to 20% of benches and add at least one armrest and locate along an AR as a smart practice (JA4, checklist)
- 1.10.4 **Replace or add one picnic table** with knee and toe clearance, 19” deep at 27” high and 24” deep at 9” high, with a 36” AR around table as a smart practice (checklist)

| Responsible Employee | Progress Towards Completion | Recommended Phase |
|---|---|-------------------|
| Amy Teegarden Director 406/447-8462 | (insert periodic notes regarding steps taken or work completed) | PHASE ONE |

1.11 Shelters/Picnic Areas - not applicable

1.12 Park Buildings - not applicable

1.13 Other - not applicable

CITY OF HELENA JANET PARK