



# REPORT TO THE CITY OF HELENA

## Section 37: Peanut Park

August 5, 2015

### Legend of Abbreviations

<b>aff...</b>	Above the finished ground
<b>AR...</b>	Accessible Route
<b>CIL...</b>	Change in Level
<b>CFS...</b>	Clear Floor Space
<b>CGS...</b>	Clear Ground Space
<b>EPC...</b>	Elevated Play Component
<b>GLPC...</b>	Ground Level Play Component

**Background**

The RAC staff visited Peanut Park to conduct an access audit. The findings are below.

**1.1 Parking – [CHECKLIST] lacks accessible parking [PP6](#)**

***Recommendations (in the alternative, leave as is and designate other sites in the City as accessible):***

**1.1.1 Create one or more 8' accessible parking stalls, with one 5' adjacent access aisle, with proper signage and striping (PP6)**

<b>Responsible Employee</b>	<b>Progress Towards Completion</b>	<b>Recommended Phase</b>
Amy Teegarden Director 406/447-8462	(insert periodic notes regarding steps taken or work completed)	CITY OPTION

**1.2 Exterior Accessible Route - [CHECKLIST] lacks EAR (checklist)**

***Recommendations:***

**1.2.1 Create AR with crushed and compacted stone or similar outdoor material from parking or sidewalk to site amenities (checklist)**

<b>Responsible Employee</b>	<b>Progress Towards Completion</b>	<b>Recommended Phase</b>
Amy Teegarden Director 406/447-8462	(insert periodic notes regarding steps taken or work completed)	CITY OPTION

**1.3 Playground Designated Entry – not applicable**

**1.4 Playground Surface/Accessible Route within - not applicable**

**1.5 Transfer System - not applicable**

**1.6 Ramps - not applicable**

**1.7 Elevated Play Components - not applicable**

**1.8 Ground Level Play Components - not applicable**

**1.9 Sand box/Play tables - not applicable**

**1.10 Park Site - [CHECKLIST]**

Benches (2): lacks CFS in grass [PP2](#), [PP3](#); lacks armrests (checklist)

***Recommendations (in the alternative, leave as is and designate other sites in the City as accessible:***

1.10.1 ***Construct firm, stable, and slip resistant pads*** at least 36” by 48” adjacent to 20% of benches, and locate along new AR as a smart practice (PP2, PP3)

<b>Responsible Employee</b>	<b>Progress Towards Completion</b>	<b>Recommended Phase</b>
Amy Teegarden Director 406/447-8462	(insert periodic notes regarding steps taken or work completed)	CITY OPTION

**1.11 Shelters/Picnic Areas** - not applicable

**1.12 Park Buildings** - not applicable

**1.13 Other** - not applicable

CITY OF HELENA PEANUT PARK