

REPORT TO THE CITY OF HELENA

Section: Dale Harris Park

September 25, 2015

Legend of Abbreviations

| | |
|----------------|-----------------------------|
| aff... | Above the finished ground |
| AR... | Accessible Route |
| CIL... | Change in Level |
| CFS... | Clear Floor Space |
| CGS... | Clear Ground Space |
| EPC... | Elevated Play Component |
| GLPC... | Ground Level Play Component |

Background

The Helena Parks and Recreation staff visited Dale Harris Park to conduct an access audit. The findings are below.

1.1 Parking – not applicable

1.2 Exterior Accessible Route - [[CHECKLIST](#)] no AR [DHP11](#), [DHP1](#), [DHP3](#)

Recommendations (in the alternative, leave as is and designate other sites in the City as accessible):

1.2.1 **Create AR** with crushed and compacted stone or similar outdoor material from parking or sidewalk to trail sign (CHP11, DHP1, DHP3)

| Responsible Employee | Progress Towards Completion | Recommended Phase |
|---|---|--------------------------|
| Amy Teegarden Director 406/447-8462 | (insert periodic notes regarding steps taken or work completed) | CITY OPTION |

1.3 Trails - [[CHECKLIST](#)] Trails meet exception (checklist); main trail head signs list rules rather trail date though provided online [DHP4](#); trail signs don't met all of 703.5 standards [DHP14](#), [DHP16](#), [DHP15](#), [DHP4](#), [DHP5](#), [DHP25](#), [DHP26](#), [DHP27](#), [DHP23](#)

Recommendations (in the alternative, leave as is and designate other sites in the City as accessible):

1.3.1 **Mount signage** at all trail heads indicating length of accessible trail segment, surface type, typical and min. tread width, typical and max. running slope, typical and max. cross slope as a smart practice (DHP4, DHP14, DHP16, DHP15, DHP5, DHP25, DHP26, DHP27, DHP23)

1.3.2 **Create** template for signs that addresses height of sign, size of characters, and other requirements (checklist)

| Responsible Employee | Progress Towards Completion | Recommended Phase |
|---|---|--------------------------|
| Amy Teegarden Director 406/447-8462 | (insert periodic notes regarding steps taken or work completed) | CITY OPTION |

1.4 Trail Features – not applicable

1.5 Other – not applicable

