



# REPORT TO THE CITY OF HELENA

## Section: Meatloaf Hill

September 25, 2015

### Legend of Abbreviations

<b>aff...</b>	Above the finished ground
<b>AR...</b>	Accessible Route
<b>CIL...</b>	Change in Level
<b>CFS...</b>	Clear Floor Space
<b>CGS...</b>	Clear Ground Space
<b>EPC...</b>	Elevated Play Component
<b>GLPC...</b>	Ground Level Play Component

**Background**

The Helena Parks and Recreation staff visited Meatloaf Hill Park to conduct an access audit. The findings are below.

**1.1 Parking** – not applicable

**1.2 Exterior Accessible Route** - [\[CHECKLIST\]](#) no AR [MH1](#), [MH2](#), [MH6](#), [MH7](#), [MH8](#), [MH9](#); no curb ramp [MH1](#), [MH2](#), [MH6](#), [MH7](#), [MH8](#), [MH9](#)

***Recommendations (in the alternative, leave as is and designate other sites in the City as accessible):***

1.2.1 **Create AR** with crushed and compacted stone or similar outdoor material from parking or sidewalk to trail sign (MH1, MH2, MH6, MH7, MH8, MH9)

1.2.2 **Create** a curb ramp to be max running slope 8.33%, max cross slope 2.08%, having a top landing as wide as the ramp and 36” deep and side flares with a max slope 10% (MH1, MH2, MH3, MH6, MH7, MH8, MH9)

Responsible Employee	Progress Towards Completion	Recommended Phase
Amy Teegarden Director 406/447-8462	(insert periodic notes regarding steps taken or work completed)	CITY OPTION

**1.3 ORAR – Trails** [\[CHECKLIST\]](#) main trail head signs list rules rather trail date though provided online [MH11](#); trail signs don’t met all of 703.5 standards [MH15](#), [MH17](#), [MH16](#), [MH15](#), [MH17](#), [MH20](#), [MH11](#)

***Recommendations (in the alternative, leave as is and designate other sites in the City as accessible):***

1.3.1 **Mount** signage at all trail heads indicating length of accessible trail segment, surface type, typical and min. tread width, typical and max. running slope, typical and max. cross slope as a smart practice (MH11, MH15, MH17, MH16, MH20, MH11)

1.3.2 **Create** template for signs that addresses height of sign, size of characters, and other requirements (checklist)

Responsible Employee	Progress Towards Completion	Recommended Phase
Amy Teegarden Director 406/447-8462	(insert periodic notes regarding steps taken or work completed)	CITY OPTION

**1.4 Trail Features** – not applicable

**1.5 Other** – not applicable