

# REPORT TO THE CITY OF HELENA

## Section: Stone Meadows

September 16, 2015

### Legend of Abbreviations

<b>aff...</b>	Above the finished ground
<b>AR...</b>	Accessible Route
<b>CIL...</b>	Change in Level
<b>CFS...</b>	Clear Floor Space
<b>CGS...</b>	Clear Ground Space
<b>EPC...</b>	Elevated Play Component
<b>GLPC...</b>	Ground Level Play Component

**Background**

The Helena Parks and Recreation staff visited Stone Meadows Park to conduct an access audit. The findings are below.

1.1 **Parking** – not applicable

1.2 **Exterior Accessible Route** - [[CHECKLIST](#)] Chert & Benton is 7.2 % on curb and gutter [SM8](#), [SM9](#); South ramp curb and gutter Flagstone & Benton is 6.4% [SM2](#), [SM3](#); Chert & Benton west flare 10.8% [SM7](#), [SM6](#); Flagstone & Benton south ramp running slope 8.8% [SM5](#), [SM4](#)

***Recommendations (in the alternative, leave as is and designate other sites in the City as accessible):***

1.2.1 **Correct slope** of adjacent street surfaces to max 5% (SM8, SM9, SM2, SM3)

1.2.2 **Correct slope** of curb ramp side flares to max 10% (SM7, SM6)

1.2.3 **Correct** curb ramp slope to max 8.33% (SM5, SM4)

Responsible Employee	Progress Towards Completion	Recommended Phase
Amy Teegarden Director 406/447-8462	(insert periodic notes regarding steps taken or work completed)	CITY OPTION

1.3 **Playground Designated Entry** – not applicable

1.4 **Playground Surface/Accessible Route within** – not applicable

1.5 **Transfer System** – not applicable

1.6 **Ramps** – not applicable

1.7 **Elevated Play Components** – not applicable

1.8 **Ground Level Play Components** – not applicable

1.9 **Sand box/Play tables** – not applicable

1.10 **Park Site** – not applicable

1.11 **Shelters/Picnic Areas** – not applicable

1.12 **Park Buildings** – not applicable

1.13 **Other** – not applicable

CITY OF HELENA STONE MEADOWS