

REPORT TO THE CITY OF HELENA

Section: Yund Park

September 11, 2015

Legend of Abbreviations

aff...	Above the finished ground
AR...	Accessible Route
CIL...	Change in Level
CFS...	Clear Floor Space
CGS...	Clear Ground Space
EPC...	Elevated Play Component
GLPC...	Ground Level Play Component

Background

The Helena Parks and Recreation staff visited Yund Park to conduct an access audit. The findings are below.

1.1 Parking –not applicable

1.2 Exterior Accessible Route - [\[CHECKLIST\]](#) Benton/Flowerree ramp has 2” lift at curb [YP1](#), [YP2](#); Neill/Park flares at 11.9% south facing flare [YP4](#); Benton/Gilbert north flare 12% [YP8](#), [YP9](#); Neill/Park running slope 9.4% east ramp [YP3](#); No detectable warnings at Benton/ Flowerree [YP2](#) or Benton/Gilbert curb ramps [YP9](#); unmarked pedestrian path at Benton/Flowerree entrance [YP2](#)

Recommendations (in the alternative, leave as is and designate other sites in the City as accessible):

- 1.2.1 Repair, bevel, or ramp CIL along AR (YP1, YP2)
- 1.2.2 Correct slope of curb ramp slide flares to max 10% (YP4, YP8, YP9)
- 1.2.3 Correct slope of ramp to max 8.33% (YP3)
- 1.2.4 Install compliant detectable warning at curb ramp as a smart practice (YP2, YP9)
- 1.2.5 Create lined cross walk where pedestrian pathway crosses through vehicular traffic as a smart practice (YP2)

Responsible Employee	Progress Towards Completion	Recommended Phase
Amy Teegarden Director 406/447-8462	(insert periodic notes regarding steps taken or work completed)	CITY OPTION

1.3 Playground Designated Entry – not applicable

1.4 Playground Surface/Accessible Route within – not applicable

1.5 Transfer System – not applicable

1.6 Ramps – not applicable

1.7 Elevated Play Components – not applicable

1.8 Ground Level Play Components – not applicable

1.9 Sand box/Play tables – not applicable

1.10 Park Site – not applicable

1.11 Shelters/Picnic Areas – not applicable

1.12 Park Buildings – not applicable

1.13 Other – Signs [[CHECKLIST](#)] smallest text used is 3/8" [YP14](#); Mix of decorative text styles [YP15](#); sign changes with the different events (checklist); 29.5" from to base of sign [YP16](#), [YP17](#)

Recommendations (in the alternative, leave as is and designate other sites in the City as accessible):

1.13.1 Replace existing signage with signage having compliant character heights and placed within proper viewing distance of the AR ([YP14](#), [YP15](#), [YP16](#), [YP17](#))

Responsible Employee	Progress Towards Completion	Recommended Phase
Amy Teegarden Director 406/447-8462	(insert periodic notes regarding steps taken or work completed)	CITY OPTION

CITY OF HELENA YUND PARK